

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 4895 / 18-10/90

Date : 14/9/26

It is certified that an inspection team headed by Shesh Mani Bind
(Junior Engineer) (Name of Officers
with designation) from Division office U.P. Jal Nigam (Rural) (Name of
Department/Office) inspected the Seth M.R. Jaipuria School.
Sarany Mahroofpur, Sandila, Hardoi. (Name & Address of
the School) on 04/09/26 and found that the Seth M.R. Jaipuria
School, Sarany Mahroofpur, Sandila Hardoi (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of one year.

Signature with Seal : 

Name : A.K. Singh

Designation : Asst. Engineer
अमित कुमार सिंह
सहायक अभियन्ता
ग्राम कार्यलय, उ०प्र० जल निगम (ग्रामीण)
हरदोई।


To

The principal
Seth M.R. Jaipuria school
Sarany Mahroofpur, Sandil, Hardoi
(Name & Address of the Institution)

अमित कु. सिंह
सहायक अभियन्ता
ग्राम कार्यलय, उ०प्र० जल निगम (ग्रामीण)
हरदोई।

JalkalVibhaghAishbagh Lucknow

It is certified that after analysis of the drinking water sample collected by the Principal, Seth M.r.Jaipuria School, Saray Maroofpur, Hardoi. the water has been found to be safe for human consumption (drinking), clean and conforming to the chemical standards. The school is providing clean drinking water for the students and staff.


Chemist

(P.K.Charyan)

CHEMIST
JALKAL VIBHAGH
NAGAR NIGAM, LUCKNOW


JalkalVibhaghAishbagh Lucknow

Date-05-09-2026

Palce of Sampling- Water sample from Seth M.R.Jaipuria School, Saray Maroofpur Sandila, Hardoi.

S.no.	Name of test	Range(is 10500/2012)	Result
1	Colour	0-5 Hazan	>5 Hazan
2	Odour	Agreeable	Agreeable
3	p ^H	6.5 to 8.5	7.5
4	Turbidity	1-5 NTU	4.0NTU
5	Chlorides	250 to 1000 mg/l.	376 mg/l
6	Ammonia	0.5 mg/l.	Nil
7	T.D.S	500 to 2000 mg/l.	356 mg/l

Note- water is drinkable.


CHEMIST 09/26
JALKAL VIBHAG
LUCKNOW
Chemist